

LOCATION 4618 Glasgow Ct. CITY Castroville

BETWEEN Abbotts Road Dr STREET & Cal-de-Sue STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>87'</u>	<u>3-22-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>6'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>81'</u>			

ENTERS 4618 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 553' W. of center of Abbotts Road Dr.


PRESSURE TEST @ 100 PSI FOR 24 HRS BY mtt.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH 3 FT 0 IN LOCATION 45' N. of center of Glasgow Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 237421

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	