

LOCATION 4619 Glasgow Ct CITY Castroville  
BETWEEN Abbotsford STREET & Cal-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>64'</u>	<u>5-18-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>59'</u>			

ENTERS 4619 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES WC LOCATION 490' W. of center of Abbotsford Ct


PRESSURE TEST @ 100 PSI FOR 4 HRS BY S. G.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED \_\_\_\_\_

DEPTH 3 FT 8 IN LOCATION 18' S. of center of Glasgow Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 409478

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	