

LOCATION 4642 Glasgow Ct CITY CASTONIA

BETWEEN Abbotsford Ct. STREET & Cal-de-Sne STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>111'</u>	<u>10-31-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>71'</u>			

ENTERS 4642 BRANCHED INTO.

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 215' W. of center of Abbotsford Ct.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. HUFF & LETH

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION 18' S. of center of Glasgow Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 743561

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	S		
P/S Pipeline Lead - White Existing Main	E		

