

LOCATION 4650 GLASGOW CT CITY GASTONIA  
BETWEEN Robotsford LN STREET & Cul-d- SAC STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4'	Plastic	99'	11/25/97		
MAIN TO PROP. LINE	3/4'		42'			
PROP. LINE TO BLDG.	3/4'		57'			

ENTERS: 4650 BRANCHED INTO:  
TAP SIZE: 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION East side of 4650

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DT  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996  
DEPTH: 3 FT 0 IN LOCATION South side of Glasgow

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 281513

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY