

LOCATION 4658 Glasgow Ct. CITY Gastonia

BETWEEN Abbott Rd STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	28'	3-4-02		
MAIN TO PROP LINE	5/8"	P	3'			
PROP LINE TO BLDG	5/8"	P	25'			

ENTERS 4658 BRANCHED INTO _____

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 87' N. of center of Glasgow


PRESSURE TEST @ 100 PSI FOR 1 1/2 HRS BY 506

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH 3 FT 0 IN LOCATION 18' W. of center of Abbott Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 042541

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main	E	