

LOCATION

609 N. GLENN ST

CITY

GAST

BETWEEN

WESTWOOD CIRCLE

STREET &amp;

WARE AVE.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	97		9-17	- 96
MAIN TO PROP. LINE	"	"	40			
PROP. LINE TO BLDG.	"	"	57			

ENTERS:

609

BRANCHED INTO:

TAP SIZE:

3/4"

PRESSURE

6.0

PSI

INCHES W.C.

LOCATION

S of 609

PRESSURE TEST: @

100

PSI

FOR

114

HRS.

BY

GK

MAIN-SIZE

2

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

96

DEPTH:

3 FT.

IN.

LOCATION

E. of N. GLENN

"A" P/S READING


P

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station

Reading &amp; Location

Lead

Volts

P/S Pipeline Lead - Red  
New Service

S

P/S Pipeline Lead - White  
Existing Main

E

ENG. DEPT. USE ONLY