

LOCATION 716 N. GlennCITY GASTONIABETWEEN WareSTREET & Essex

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>85' Existing</u>	<u>Tie-over to 2" Plastic</u>		
MAIN TO PROP. LINE				<u>w/ 1' 3/4</u>		
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 228 South
of Essex


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By R Hayes

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 Ft. In. _____ LOCATION 16 East of N Glenn

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Tie-over Existing 3/4 to 2" Plastic



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY