

LOCATION 2227 Glenraven Ave. CITY Gastonia  
BETWEEN Davis Park Rd. STREET & Hartford Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	104'	1-21-03		
MAIN TO PROP LINE	5/8"	P	10'	"		
PROP LINE TO BLDG	5/8"	P	54'	"		

ENTERS 2227 BRANCHED INTO 0  
TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 5491 East


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY D. Woody at center of Davis Park Rd.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1969

DEPTH 3' - FT 0" IN LOCATION 11' south of center of Glenraven Ave.

"A" P/S READING 1.3 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # 00006090

REMARKS New Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	