

LOCATION

2434 Glenridge DR.

CITY

COSTA MESA

BETWEEN

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	138'	12-6-95		
MAIN TO PROP. LINE	3/4"	P	45'			
PROP. LINE TO BLDG.	3/4"	P	85'			

ENTERS: 2434

BRANCHED INTO:

TAP SIZE: 1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

223' S. of center of

Brookwood DR

PRESSURE TEST: @

100

psi

For

1/4

Hrs.

By

S. Huffstet

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1995

DEPTH:

3 Ft.

0 In.

LOCATION

12' W. of center of Glenridge DR

"A" P/S READING

P


TOTAL ANODES

1# 0 17# 0

L.R. #

620590

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E