

LOCATION 2450 Glenridge Dr. CITY GASTONIA

BETWEEN Grayland Ct STREET & Georgetown Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>27'</u>	<u>12-12-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>22'</u>			

ENTERS: 2450 BRANCHED INTO:

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 106 E. of center of

Glenridge Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstetler

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION 19' S. of center of Grayland Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 850343

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY