

LOCATION 2637 Goble St CITY GASTONIA
BETWEEN Propst STREET & Hill St STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>399'</u>	<u>9-12-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>280'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>119'</u>			

ENTERS: 2638 BRANCHED INTO: 2637
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W/C LOCATION 612' E of Propst St.

PRESSURE TEST @ 100 PSI. FOR 1/4 HRS BY RL
MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1980
DEPTH: 2 FT. 0 IN. LOCATION 13' S of C of Goble St

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 L.R. # 609945

REMARKS: Split Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY