

LOCATION 2809 Goble St. CITY Gastonia
BETWEEN Midway Dr. STREET & Birchfield Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	54'	7-8-02		
MAIN TO PROP LINE	5/8"	P	6'	"		
PROP LINE TO BLDG	5/8"	P	48'	"		

ENTERS 2809 BRANCHED INTO 0

TAP SIZE 1/2" PRESSURE 60 PSI INCHES W.C. LOCATION 198' south of

center of Midway Dr.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH 3' FT 0" IN LOCATION 12' west of center of Goble St.

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 4 LR # 00179700

REMARKS New plastic service

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	plastic

