

LOCATION 1239 Golf Course Dr. CITY GASTONIA  
BETWEEN Stevens St STREET & Kelly Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>130'</u>	<u>9-23-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>42'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>88'</u>			

ENTERS: 1239 BRANCHED INTO: 0  
TAP SIZE: 3/8 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 307' N of Stevens St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1969

DEPTH: 3 Ft. 0 In. LOCATION 18' E of C of Golf Course Dr.

"A" P/S READING .90 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: New 3/4 Plastic Service with Road Bore.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY