

LOCATION

615 + 617^{W.} Granite Ave.

CITY

Gastonia

BETWEEN

Cherry St

STREET &

N. Pryor St

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	30'	5-4-96		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

615

BRANCHED INTO:

617

TAP SIZE:

1/2

PRESSURE

600

P.S.I.

INCHES W.C.

LOCATION

268' E. of center of

N. Pryor St

PRESSURE TEST: @

105 psi

For 44 Hrs.

By S. Huffy, Leth

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

1994

DEPTH:

3 Ft.

0 In.

LOCATION

12' N. of center of W. Granite Ave

"A" P/S READING


P

TOTAL ANODES

1# 0 17# 0

L.R. #

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	