

LOCATION 616 & 618 W. Granite Ave. CITY Gastonia  
BETWEEN Mohr 2.5 STREET & Prior STREET


	SIZE	TYPE	616 LENGTH 618		INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>28</u>	<u>12'</u>		<u>618 W. GRANITE AVE.</u> <u>12' of 1" BARE</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>2'</u>	<u>1'</u>		<u>5-25-94</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>26'</u>	<u>11'</u>		<u>616 W. GRANITE AVE.</u> <u>28' of 1" BARE</u>	

ENTERS: 616 BRANCHED INTO: 618  
TAP SIZE: 1" Ser. PRESSURE 20 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION

PRESSURE TEST: @ 100 psi For 1 1/2 Hrs. By EP  
MAIN-SIZE 1" C.I. \_\_\_\_\_ BARE STEEL ☒ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1987  
DEPTH: 2 Ft. 0 In. LOCATION

"A" P/S READING .5 TOTAL ANODES 1\* 1 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY