

LOCATION 620 W. Granite Ave. CITY MAST.  
BETWEEN PRYOR STREET & CHERRY STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	33'		4 - 26 - 96	
MAIN TO PROP. LINE	"	"	4'			
PROP. LINE TO BLDG.	"	"	29			

ENTERS: 620 W. GRANITE BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI          INCHES W.C. LOCATION W. side of 620

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GK  
MAIN-SIZE 2 C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 96  
DEPTH: 3 FT. IN.          LOCATION N. side of W. Granite

"A" P/S READING P TOTAL ANODES 1#          17#          L.R. #         

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY