

|                     |                    |         |        |           |                           |         |  |
|---------------------|--------------------|---------|--------|-----------|---------------------------|---------|--|
| LOCATION            | 1200 Graystone Dr. |         |        | CITY      | Gastonia                  |         |  |
| BETWEEN             | Carlton Dr         |         |        | STREET &  | STREET                    |         |  |
|                     | SIZE               | TYPE    | LENGTH | INSTALLED | RETIRED                   | RENEWED |  |
| MAIN TO BLDG.       | 3/4"               | Plastic | 5'     | 5-24-94   | Tied over 93' of          |         |  |
| MAIN TO PROP. LINE  |                    |         |        |           | Existing 3/4" c/w Service |         |  |
| PROP. LINE TO BLDG. |                    |         |        |           | at 1200                   |         |  |

ENTERS: 1200 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 88' E. of center of

Carlton Dr


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S.H.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. In. LOCATION 16' N. of center of Graystone Dr

"A" P/S READING 1.2 TOTAL ANODES 1# 1 17# 0 L.R. #

REMARKS: Tied off wire at TEE



| Test Station                               |      |       |
|--|------|-------|
| Reading & Location                         | Lead | Volts |
| P/S Pipeline Lead - Red<br>New Service     | S    |       |
| P/S Pipeline Lead - White<br>Existing Main | E    |       |

ENG. DEPT. USE ONLY