

LOCATION 1215 Graystone Dr CITY Gastonia
 BETWEEN Kemsuick Dr. STREET & Carlton Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	4'	5-21-94	Tied over	140' 3/4"
MAIN TO PROP. LINE					Existing	City Service
PROP. LINE TO BLDG.						

ENTERS: 1215 BRANCHED INTO:
 TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 198' W. of center of Kemsuick Dr.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S.H
 MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993
 DEPTH: 3 Ft. In. LOCATION 21' N. of center of Graystone Dr

"A" P/S READING 1.2 @ 0 TOTAL ANODES 1* 1 17* 0 L.R. #

REMARKS: Tied wire off at Main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY