


LOCATION 1917 Graystone Dr.CITY GASTONIABETWEEN Grey stone Ct.STREET & 1912 Grey stone Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	115'	10-7-94		
MAIN TO PROP. LINE	3/4	Plastic	18'			
PROP. LINE TO BLDG.	3/4	Plastic	97'			

ENTERS: 1917BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 322' N of 1917 Grey stone Ct.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BLMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1994DEPTH: 3 Ft. 0 In. LOCATION 14' W of 1917 Grey stone Dr."A" P/S READING Plastic TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # 419403

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY