

LOCATION 3139 Gray stroke CITY Gastonia  
 BETWEEN Greenmont STREET & Dead end STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>107</u>	<u>5-18-99</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>1"</u>	<u>13</u>			
PROP LINE TO BLDG	<u>1"</u>	<u>1"</u>	<u>9.5</u>			

ENTERS 3139 BRANCHED INTO 0  
 TAP SIZE 3/4 PRESSURE 60 PSI INCHES W.C. LOCATION 585' N of C of Greenmont

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY MC  
 MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996  
 DEPTH 3 FT IN LOCATION 17' E of C of Gray stroke.

\*A\* P/S READING P TOTAL ANODES 1# - 17# - LR # -

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	