

LOCATION 3907 Graywood Dr. CITY CASTON, PA

BETWEEN Laurel Woods Dr. STREET & Dead End. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>148'</u>	<u>7-11-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>113'</u>			

ENTERS: 3907 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI  INCHES W C LOCATION 512' E of center of

Laurel Woods Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Hudgrette

MAIN-SIZE 2" C.I.  BARE STEEL  COATED STEEL  PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION 15' S. of center of Graywood Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 438736

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY