

LOCATION 119 Green Dr. CITY EAST.
BETWEEN EAST CLUB STREET & FRANKLIN BLVD STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>107'</u>		<u>12-</u>	<u>17-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>101'</u>			

ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 166' from G SF
EAST CLUB

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1987
DEPTH: 3 FT 0 IN LOCATION W. SF Green Dr.

"A" P/S READING P. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY