

LOCATION 1216 Green circle CITY GAS.
BETWEEN Parkview Dr. STREET & Midway Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P.	69'		8-	12-97
MAIN TO PROP. LINE	"	"	13'			
PROP. LINE TO BLDG.	"	"	56'			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 186' From ⓪ of
Parkview Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY O.F.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION S. of Green circle

"A" P/S READING _____ TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY