

LOCATION 2140 Greenleaf Dr. CITY Bostonia  
BETWEEN Ridge Wood Dr. STREET & Perry St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>77'</u>	<u>6-27-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>				
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>				

ENTERS: 2140 BRANCHED INTO: 0  
TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 494' S of Cor Perry St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL V PLASTIC \_\_\_\_\_ YEAR INSTALLED 1966  
DEPTH: 3 FT. 0 IN. LOCATION 25' W of Cor Greenleaf Dr.

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # 343970

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser plastic</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY