

LOCATION <sup>109</sup> Green Meadow Ct. CITY GASTONIA  
BETWEEN Patrick Rd. STREET & Dead End. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	136'	1-19-96	96' Existing	3/4 Plastic
MAIN TO PROP. LINE	3/4	Plastic	20'		GAS Pipe.	IN WAY OF
PROP. LINE TO BLDG.	3/4	Plastic	116'		Septic Tank.	Relocated.

ENTERS: 109 BRANCHED INTO: 0 <sup>Service</sup>

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 350' W of Coy Patrick Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 FT. 6 IN. LOCATION 30' S of Coy Green Meadow Ct.

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. #

REMARKS: Used 50' Existing 3/4 P. Stub where Pipe WAS Retired.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY