

LOCATION 111 Green Meadow St CITY Gastonia
BETWEEN Union Rd STREET & dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>124'</u>	<u>10-14-99</u>		
MAIN TO PROP LINE	<u>1/2</u>	<u>"</u>	<u>20'</u>			
PROP LINE TO BLDG	<u>1/2</u>	<u>"</u>	<u>104'</u>			

ENTERS 111 BRANCHED INTO ~
TAP SIZE 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 40' W. of Cap


PRESSURE TEST 100 PSI FOR 14 HRS BY JP CAL d. SAE

MAIN SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH 3 FT 12 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	