

LOCATION 112 Green Meadow Ct. CITY GASTONIA

BETWEEN Patrick Rd STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3 1/4"</u>	<u>P</u>	<u>126'</u>	<u>3-26-97</u>		
MAIN TO PROP. LINE	<u>3 1/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3 1/4"</u>	<u>P</u>	<u>116'</u>			

ENTERS: 112 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 398' NW. of center of Patrick Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUFFSOUTH

MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED       

DEPTH: 3 FT. 0 IN. LOCATION 7' NE of center of Green Meadow Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 172225

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<b>S</b>		
	P/S Pipeline Lead - White Existing Main	<b>E</b>		