

LOCATION 1110 Greenwich Terrace CITY Gastonia
BETWEEN Overhill STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>148'</u>	<u>2-14-01</u>	<u>Retired 68' of 3/4" old</u>	
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>		<u>Purged with Air &</u>	
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>143'</u>		<u>Foamed.</u>	

ENTERS Same BRANCHED INTO
TAP SIZE: 1/4 PRESSURE 60 PSI INCHES W C LOCATION 35' East of

Greenwich Terrace & 205' South of Overhill St


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. Ballard

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1960
DEPTH 3 FT 0 IN LOCATION 35' East of Greenwich Terrace.

"A" P/S READING 1.3 TOTAL ANODES 1# 17# L R #

REMARKS

New Plastic Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>p. Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	