

LOCATION 1114 Greenwich Terrace CITY Gastonia
BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>90'</u>	<u>2-14-01</u>	<u>Retired 75' of 3/4"</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>	<u>ctw. Purged with Air &</u>		
PROP. LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>85'</u>	<u>Foamed.</u>		

ENTERS _____ BRANCHED INTO _____
TAP SIZE 1/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 35' East of
Greenwich Terrace + 183' South of Overhill St.


PRESSURE TEST. @ _____ PSI FOR _____ HRS BY _____

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1960

DEPTH 3 FT 0 IN LOCATION 35' East of Greenwich Terrace.

"A" P/S READING 1.3 TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS Retired & Renewed Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>p. Riser.</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	