

LOCATION 2517 Grayland Ct. CITY Gastonia  
BETWEEN Glennridge Dr. STREET & Cut-ct-Str. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	111'	3-17-98		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	106'			


ENTERS: 2517 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 863' E. of center of Glennridge Dr

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hufford  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION 38' S. of center of Grayland Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 707009

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY