

LOCATION 4608 Grier st CITY Gastonia  
BETWEEN Homestead STREET & Plaza STREET

|                     | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG.       | 3/4  | P    | 121    | 10-11-96  |         |         |
| MAIN TO PROP. LINE  | 1"   | "    | 45'    |           |         |         |
| PROP. LINE TO BLDG. | 1"   | "    | 76'    |           |         |         |

ENTERS: 4608 BRANCHED INTO: 0  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 231' S of C of Homestead

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY BC

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. \_\_\_\_\_ IN. LOCATION 17' E of C of Grier

"A" P/S READING Plastic TOTAL ANODES 1# - 17# - L.R. # 00570455


REMARKS:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



| Test Station                               |           |          |
|--|-----------|----------|
| Reading & Location                         | Lead      | Volts    |
| P/S Pipeline Lead - Red<br>New Service     | <u>SR</u> | <u>P</u> |
| P/S Pipeline Lead - White<br>Existing Main | <u>E</u>  |          |

ENG. DEPT. USE ONLY