

LOCATION 4113 GRASSON ST CITY COLUMBIA
 BETWEEN OLD YORK RD. STREET A STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	116'	12-7-99		
MAIN TO PROP LINE	3/4	P	40'			
PROP LINE TO BLDG	3/4	P	76'			

ENTERS 4113 BRANCHED INTO 0

TAP SIZE 1/2 PRESSURE 60 PSI INCHES WC LOCATION

PRESSURE TEST 0 100 PSI FOR 14 HRS BY EP

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993

DEPTH 3 FT 0 IN LOCATION

"A" P/S READING 0 TOTAL ANODES 1# — 17# — L.R. #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	<u>0.120</u>
P/S Pipeline Lead White Existing Main	E	

