

LOCATION 4133 Grissom St. CITY CANTONIA
BETWEEN KICKAPOO LN. STREET & Old York Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>150'</u>	<u>1-5-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>110'</u>			


ENTERS: 4133 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 646' W of Co of Kickapoo LN.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 4 FT. 0 IN. LOCATION 16' N of Co of Grissom St.

"A" P/S READING Plastic W/A TOTAL ANODES 1# 0 17# 0 L.R. # 873328

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY