

LOCATION 4202 GRISSON ST. CITY Gastonia
BETWEEN old york Rd STREET & Kickapoo STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|------------|-------------|-----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>139</u> | <u>11-16-98</u> | | |
| MAIN TO PROP. LINE | <u>1/2</u> | <u>1/2</u> | <u>7</u> | | | |
| PROP. LINE TO BLDG. | <u>1/2</u> | <u>1/2</u> | <u>132'</u> | | | |

ENTERS: 4202 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 16' N. of cap
GRISSON


PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY AP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING 0 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

|  | Test Station | | ENG. DEPT. USE ONLY |
|---|--|----------|---------------------|
| | Reading & Location | Lead | |
| | P/S Pipeline Lead - Red New Service | <u>R</u> | |
| | P/S Pipeline Lead - White Existing Main | <u>E</u> | |