

LOCATION 4215 Grisson St. CITY GASTONIA
BETWEEN Kickapoo STREET & Old York STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>131'</u>	<u>12-15-97</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>57'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>74'</u>			

ENTERS: _____ BRANCHED INTO: _____
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 175 N C of Kickapoo

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY MDS. (Smitty)
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997
DEPTH: 3' FT. — IN. LOCATION 19 FT E Grisson St.

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY