

LOCATION 4226 Grissom St. CITY Gastonia
BETWEEN Old York Rd STREET & KickAPOO AVE. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>88'</u>	<u>2-23-2000</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>83'</u>			

ENTERS: 4226 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 66 PSI _____ INCHES W.C. LOCATION W side of 4226

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 2000
DEPTH: 3 FT. IN. LOCATION N. side of Grissom

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY