

LOCATION 509 Grovant Ct. CITY Gastonia N.C.  
BETWEEN Ingonish Dr. STREET & Cape Breton TR. STREET

|                   | SIZE        | TYPE      | LENGTH     | INSTALLED      | RETIRED | RENEWED |
|-------------------|-------------|-----------|------------|----------------|---------|---------|
| MAIN TO BLDG      | <u>5/8"</u> | <u>P</u>  | <u>77'</u> | <u>12-5-01</u> |         |         |
| MAIN TO PROP LINE | <u>..</u>   | <u>..</u> | <u>5'</u>  |                |         |         |
| PROP LINE TO BLDG | <u>..</u>   | <u>..</u> | <u>72'</u> |                |         |         |

ENTERS 509 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W/C LOCATION W. side of 509


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY T. Cain

MAIN-SIZE 2" C I     BARE STEEL     COATED STEEL     PLASTIC     YEAR INSTALLED ?

DEPTH 3 FT IN     LOCATION S. side of cul de sac

"A" P/S READING     TOTAL ANODES 1#     17#     LR #    

REMARKS.  
     
     
     
   



| Test Station                            |          |       |
|---|----------|-------|
| Reading & Location                      | Lead     | Volts |
| P/S Pipeline Lead - Red New Service     | <u>S</u> |       |
| P/S Pipeline Lead - White Existing Main | <u>E</u> |       |