

LOCATION 818 GROVES ST. CITY Gastonia (Lowell)
BETWEEN 74 STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>117'</u>	<u>11-19-99</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>1"</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>1"</u>	<u>1"</u>	<u>77'</u>			

ENTERS 818 BRANCHED INTO
TAP SIZE 1/2 PRESSURE _____ PSI _____ INCHES W C LOCATION 21' E. of Cop

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY JP Groves

MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 FT 2 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

