

LOCATION 506 Grouant St. CITY DANSTONIA
 BETWEEN Ingonish Dr. STREET & End of Calderack STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>65'</u>	<u>9-29-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>5'</u>			
PROP. LINE TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>60'</u>			

ENTERS 506 BRANCHED INTO 0
 TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 212' E of C of Ingonish

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL
 MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998
 DEPTH 3 FT 6 IN LOCATION 28' S of C of Grouant St.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 I.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

COPY