

LOCATION 1818 GUM ST. CITY GASTONIA
BETWEEN GROVER ST. STREET & MS FARLAND ST. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG | 3/4" | P | 60 | 5.23.00 | | |
| MAIN TO PROP LINE | " | " | 5' | | | |
| PROP LINE TO BLDG | " | " | 55' | | | |

ENTERS SAME BRANCHED INTO
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION E. of 1818


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY BL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT IN LOCATION N. side of Gum St

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ I.R. # _____

REMARKS.



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |