

LOCATION 114 HAMRICK RD. CITY CASTONIA

BETWEEN CRAMER MTN RD. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>71'</u>	<u>07/06/95</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>11'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>60</u>			

ENTERS: 114 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BJ


MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 Ft. 6 In. LOCATION 337' S. of C of CRAMER MTN RD. 13' E. of C of

 HAMRICK RD.

"A" P/S READING P TOTAL ANODES 1* P 17* P L.R. # 00286573

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY