

LOCATION 145 HAMRICK Dr. Bldg. A. CITY GASTONIA
BETWEEN Cramer Mt. Rd. STREET & End of Rd. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>256'</u>	<u>1-31-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>26'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>230'</u>			

ENTERS: 145 Bldg. A. BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI 1 INCHES W.C. LOCATION 1330' E of Cramer Mt. Rd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995
DEPTH: 4 FT. 0 IN. LOCATION 12' S of HAMRICK Dr.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 I.R. # 040480

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Rise PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY