

LOCATION 209 HANCOCK ST. CITY GASTONIA

BETWEEN INDUSTRIAL STREET & AIRLINE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>117'</u>		<u>6-9-97</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>112'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION EAST SIDE OF 209


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY B.T.

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED _____

DEPTH: 3 FT. 6 IN. LOCATION SOUTH SIDE OF HANCOCK

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY