

LOCATION 515 Hardy ALLEY CITY GASTONIA
BETWEEN OAKLAND ST. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>44'</u>			<u>2-6-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>P</u>	<u>7'</u>		<u>58' of 3/4" cfw</u>	
PROP. LINE TO BLDG.	<u>"</u>	<u>P</u>	<u>37'</u>			

ENTERS: 515 Hardy ALLEY BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 11' west of Hardy ALLEY


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY MLP

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION West Side of Hardy ALLEY

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY