


LOCATION 1506 HARGOVE LOT 32 CITY GASTONIABETWEEN CLOVERDALE STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>125'</u>	<u>01/04/96</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>110'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>15'</u>			

ENTERS: 1506 BRANCHED INTO: _____TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 75' W OF C. OFCLOVERDALE CIRPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RLMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1972DEPTH: 3 FT. 6 IN. LOCATION 15' S OF C. OF CLOVERDALE"A" P/S READING 1.2 TOTAL ANODES 1# — 17# — L.R. # 00003812

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY