


LOCATION - 909 Harper Rd CITY Gastonia  
BETWEEN Union Rd STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>112'</u>	<u>5-18-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>50'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>62'</u>			

ENTERS Same BRANCHED INTO  
TAP SIZE. 1/4" PRESSURE 60 PSI INCHES W C LOCATION 19' South of Harper Rd +  
406' East of Union Rd.

PRESSURE TEST @ 100# PSI FOR 1/4 HRS BY B. BALLARD  
MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1988  
DEPTH 4 FT 0 IN LOCATION 19' South of Harper Rd.

"A" P/S READING Plastic TOTAL ANODES 1# — 17# — L.R. # 00421305  
REMARKS New Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P. Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	