

LOCATION 1202 Harper Rd CITY Castroville
BETWEEN Davenport STREET & EAST Ridge STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>80'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>	<u>11-4-95</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>70'</u>			

ENTERS: 1202 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 114 Hrs. By EP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# 17# _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY