

LOCATION 801 E. HARRISON CITY GASTONIA  
BETWEEN N. Rhyne STREET & N. Aven STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8</u>	<u>PL</u>	<u>103'</u>			<u>7-18-02</u>
MAIN TO PROP LINE	<u>5/8</u>	<u>PL</u>	<u>11'</u>			
PROP LINE TO BLDG	<u>5/8</u>	<u>PL</u>	<u>92'</u>			

ENTERS 801 BRANCHED INTO  
TAP SIZE 5/8 PRESSURE 60 PSI INCHES W C LOCATION

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SE

MAIN-SIZE 6" C I      BARE STEEL      COATED STEEL ✓ PLASTIC      YEAR INSTALLED 1955

DEPTH 7 FT 0 IN LOCATION

"A" P/S READING 1.050 TOTAL ANODES 1# 17# LR #     

REMARKS

97' 1" Bare Retire MAIN 7' Deep

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>1254</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

