

LOCATION 107 W. Harrison Ave CITY Cast.

BETWEEN N. Marietta St. STREET & Logan St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>86'</u>			<u>9-13-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>81'</u>			

ENTERS: Sam BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI  INCHES W.C. LOCATION 65' East from @ of Logan St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY Sam

MAIN-SIZE 2" C.I.  BARE STEEL  COATED STEEL  PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 3 FT. 0 IN. LOCATION South side of W. Harrison Ave.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>S</u>		
P/S Pipeline Lead - White Existing Main	<u>E</u>		

