

LOCATION 110 & 108 & 106 W Harrison CITY GAstonia
BETWEEN Logan STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	216	712 over 11/23/96		
MAIN TO PROP. LINE	3/4"		28'			
PROP. LINE TO BLDG.	3/4"		188			


ENTERS: 110 & 108 & 106 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION N side of 110
W side of 108
W side of 106

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS: Tied over 63' of ex 3/4" Plastic ser to 110 W Harrison to new main
tied over 43' of ex 3/4" Plastic ser to 108 to new main
Tied over 82' of ex 3/4" Plastic ser to 106 to new main
28' of 3/4" Plastic used to tie over split services



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY